



Domestic/Landlord Gas Safety Record

Safety inspection and reporting carried out in accordance with Gas Safety (Installation and Use) Regulations and the Gas Industry unsafe Situations Procedure

No detailed internal inspection of flues (Integrity, Constructions and lining) has been carried out

Certificate Reference

29 Adelaide Road

Certificate No: 00053

Engineers Details

Trading Title

Haymans Plumbing And Heating

Address

7 Haymans Green
West Derby
Liverpool

Post Code: L12 7JG

Gas Safe No:

147565

Telephone No:

07738154980

Installation Details

Installation Address

29 Adelaide Road

Post Code:

CH48 2HE

Client Details

Client Address

P.fear
Greenbank
5 Caldys Road
West Kirby Wirral

Telephone No:

01516250374

Appliance Details

Inspection Details

Location	Appliance Type	Make	Model	Flue Type (OF/RS/FL)	Appliance Inspected (YES/NO/NA)	Combustion Analysis Reading (CO/CO2)	Landlords Appliance (YES/NO/NA)	Operating Pressure (mbar) or Heat Input (kW)	Safety Device(s) Correct (YES/NO/NA)	Ventilation Provision (YES/NO/NA)	Visual Condition Of Flue and Termination (YES/NO/NA)	Flue Performance Test (PASS/FAIL/NA)	Appliance Serviced (YES/NO/NA)	Appliance Safe To Use (YES/NO)
Kitchen	Combi boiler	Ideal	INDEPENDENT	RS	YES	8.2	YES	16 mbar	YES	N/A	N/A	N/A	NO	YES
Kitchen	Hob	Lamona	4 Ring Stainless	OF	YES	Na	YES	6 mbar	YES	YES	N/A	N/A	NO	YES

Faults/Notes

Remedial Work Taken

Warning Notice Fixed

Emergency Control Valve accessible:

YES

Gas Tightness Satisfactory:

YES

Gas Installation Pipework Visual Inspection Satisfactory:

YES

Number Of Appliances Tested:

2

Equipment Bonding:

YES

Installation Pass:

Fri-19-06-2015

Signatures

Report Issued By:

Name: Tarron Bish

Signed:

Date: Thu-19-06-2014

Gas ID Number: 3207321

NEXT INSPECTION DUE ON OR BEFORE:

Fri-19-06-2015

Installation Pass:

YES

Report Received By:

Name: P.fear

Signed:

Date: Thu-19-06-2014