

Serial No
JB60182

Registered Business/engineer details can be checked at www.gassaferegister.co.uk or by calling 0800 408 5500.

G7 MECHANICAL LTD GAS SAFETY RECORD

This record can be used to document the outcomes of the checks and tests required by The Gas Safety (Installation and Use) Regulations 1998 as amended by the Gas Safety (Installation and Use) (Amendment) Regulations 2018. Some of the outcomes are as a result of visual inspection only and are recorded where appropriate. Unless specifically recorded no detailed inspection of the flue lining, construction or integrity has been performed.

Gas safe is a registered trade mark of HSE and is used under licence.



Details of Registered Business

Gas Safe Register No **624427**

Registered Engineer's Name **GRANT PAUL WALTON**

Gas Safe Register Licence Number _____

Business **G7 MECHANICAL LTD**

Address **49A HIGH STREET NOTTINGHAM**

Postcode **NG15 7AW**

Contact No **0115 9630 056**

Details of Site

Name (Mr/Mrs/Miss/Ms) **Stacy Lynn Lukes Ferguson**

Address **Grace Street LEEDS LS1 2FN**

Postcode _____

Contact No _____

Details of Customer/Landlord (or agent where appropriate)

Name (Mr/Mrs/Miss/Ms) **As Above.**

Address _____

Postcode _____

Contact No _____

Number of Appliances tested **02**

Appliance Details									
	Location of	Type	Manufacturer	Model	Owned by Landlord/Homeowner Yes/No	Inspected Yes/No	Type of flue		
1	Plantroom	Boiler	HYDENS	60C	Yes	Yes	BT		
2	Plantroom	Boiler	HYDENS	60C	Yes	Yes	CF		
3									
4									

Inspection Details										
	Operating pressure in mbar and/ or heat input kW/h or Btu/h	Operation of safety device(s)	Ventilation satisfactory	Visual condition of flue and termination	Flue operation checks	Combustion analyser reading (if applicable)	Appliance serviced	CO Alarm fitted	CO Alarm tested (if fitted)	SAFE TO USE
1	21	Pass	Yes	Pass	Pass	6.00009	Yes	Yes	Pass	Yes
2	21	Pass	Yes	Pass	Pass	6.00008	Yes	Yes	Pass	Yes
3										
4										

Safety Related Defect(s) Identified			GIUSP classification eg. AR, ID	Warning/Advisory Record insert form serial No*
1				
2				
3				
4				
Remedial Action Taken numbering should correspond to defects above.				
Details of Work carried out				
Boiler service to both boilers - (fail)				
Boiler 1 & 3 - new PCB & display to boiler 3.				

select as appropriate and relevant

Outcome of gas installation pipework visual inspection? **Pass / Fail / NA**

Outcome of gas supply pipework visual inspection? **Pass / Fail / NA**

Is the Emergency Control Valve access satisfactory? **Pass / Fail / NA**

Outcome of gas tightness test? **Pass / Fail / NA**

Is the Protective Equipotential bonding satisfactory? **Pass / Fail**

Record issued by: Signature **G. Walsh**

Print Name **GRANT WALTON**

Received by: Signature **Nuf Present**

Date appliance(s)/flue(s) checked **3/19/24**

Tenant/Landlord/Homeowner/Agent

ATTENTION

Next safety check due by: **09/25**

See Notice A and B